

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 97

Dated: 30.04.2025

It is certified that an inspection team headed by Vaibhav Suman (Asst. Engineer)

(Name of Officers with designation) from P.H. Sub-Division Sitamarhi

(Name of Department/ Office) inspected the CP Indraprastha International School,
Baligaon, Rummisaidpur(Name & Address of the school) on 29.04.2025 (date of inspection) and found that the
CP Indraprastha International School (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of One year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department:

To

The Principal

CP Indraprastha International School

Baligaon, Rummisaidpur, Sitamarhi

(Name & Address of the Institution)

Sumee
30/04/2025

VAIBHAV SUMAN

ASST. ENGINEER

PHED,

Sitamarhi

S.D.O.

P.H. SUB DIVISION
SITAMARHI

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

PUBLIC HEALTH DIVISION SITAMARHI
WATER QUALITY TEST REPORT

DISTRICT- SITAMARHI

MONTH/YEAR

30.04.2025

NAME OF DIVISION: Sitamarhi Division

SL. No.	Block	Panchayat	Source/Ward	Name of School	pH	Conductivity (µS/cm)	Total Hardness (mg/L)	Chloride (mg/L)	Turbidity	Tds	Calcium	Magnesium	Alkanity	Nitrate (mg/L)	Iron (mg/L)	Sulphate	Remarks
1	Runni saidpur	Balgarh	Submersible	CP Indraprastha International School	7.5	565	164	55	3	268	58	24	185	2.5	0.20	14.00	SAFE
Acceptable limit					9		200	250	1	500	75	30	200	45.0	1.0		
					600	1000	5	2000	100	100	600	NR	NR				

Chemist
Shyamsingh
30/04/2025
P. H. Division Sitamarhi

A.E
Shyamsingh
30/04/2025
P. H. SUB DIVISION
SITAMARHI